

Water Quality Test Report Laboratory

PHE & WS Division:Longding

Block :-Kanubari.

Location:-Govt. Higher Secondary School Kanubari.

Source :- Tank.

Date :-02-09-2026

Sl. no	Parameters	Unit	Requirement (Acceptable Limit)	Permissible Limit	Lab Test Report
1	PH		6.5	8.5	7
2	Turbidity	NTU	1	5	1.03
3	Total Hardness	Milligram/Litre	200	600	20
4	Chloride	Milligram/Litre	250	1000	0.5
5	Iron	Milligram/Litre	1	No relaxation	0.0
6	Residual Chlorine	Milligram/Litre	0.2	1	0.0
7	Nitrate	Milligram/Litre	45	No relaxation	0.63
8	Fluoride	Milligram/Litre	1.0	1.5	0.02
9	Total Alkalinity	Milligram/Litre	200	600	15
10	TDS	Milligram/Litre	500	2000	21
11	Bacterial	Total Coliform			Absent

Certificate

Certified that the water sample collected from Govt. Higher Secondary School, Kanubari has been tested and found potable as per the above test results.


Laboratory Assistant
PHE & WS Division,
Longding


(Er. Gunge Ete)
Lab. In-charge (ASW)
PHE & WS Division
Longding