



GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE SUPERINTENDENT OF POLICE
LONGDING DISTRICT: LONGDING

NO. DDAPP/R/F&ES-94/2018-25

Dated Longding the 10th August'2026


//NO OBJECTION CERTIFICATE//

In pursuance of the inspection conducted by the officer concern of Fire & Emergency Service Station Longding and report submitted thereafter, this office has No Objection to the fire safety measures installed at "Govt. Higher Secondary School, Kanubari" PO/PS-Kanubari, District Longding, Arunachal Pradesh.

This certificate may be treated as No Objection Certificate/ Fire Safety Certificate for the period of 06 (Six) months from date of issuance and is to be considered as a Provisional Certificate pending formulation of Fire Safety Rules/Norms by the Government of Arunachal Pradesh, consequent to which a further inspection will be carried out and the new norms will have to be adhered to.

Condition for the validity of Fire Safety Certificate under:

1. All the means of escape/emergency exit shall be kept free from any type of obstruction all the time.
2. All the staffs/employees shall be acquainting with the use and maintenance of all fire equipment and method of speedy and safe evacuation in case of emergency.
3. All the firefighting equipment shall be maintained in perfect working condition and any lapse rendering non-functional of fire safety measures, the management shall be responsible for such lapse.
4. Any deviation with regards to construction, ventilation, occupation, electric installation etc. may not be verified from the concerned authority.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/authorized use of land, if any.
6. The owner/occupier shall apply for renewal of this certificate on two months prior to its expiry date.


(Dekio Gumja) APPS
Superintendent of Police
Longding District: Longding

P.T.O

SUPERINTENDENT OF POLICE
LONGDING DISTRICT: LONGDING
ARUNACHAL PRADESH